



PARKING GARAGE



GOOD

- 8 ft strip light
- Versatile and inexpensive
- All three options meets IES recommendation for parking garage facilities
- Less equipment cost but higher installation cost
- Hot spots under the fixtures and glare is a concern


A



BETTER

- Vapor tight and wet location listed
- Vandal resistant with polycarbonate lens
- All three options are available with standalone wired/wireless ambient and motion sensors to comply with T24
- Driveways and parking stalls are well illuminated but glare is a concern

B



BEST

- LITHONIA VCPG - Upscale and architecturally pleasing
- Visually comfortable lens designed to bring glare control
- Premium wide optic allows single row layout while meeting IES requirements
- Most cost effective installation when comparing fixture + labor
- Uniform lighting throughout with uplight component to eliminate cave effects

C

PARKING GARAGE

2.6	4.0	2.7	2.0	3.4	3.8	2.2
6.2	16.1	6.4	3.1	10.7	13.9	3.9
3.9	7.4	3.9	2.5	5.6	6.7	2.8
2.1	2.7	2.2	1.8	2.5	2.7	1.9
3.7	7.0	3.8	2.4	5.3	6.4	2.7
6.1	16.2	6.2	3.0	10.7	13.9	3.7
2.3	3.8	2.4	1.7	3.1	3.5	1.8

GOOD

- 4.7 fc avg - 1.7 fc min - 9.7 max/min
- Equipment Cost \$
- Labor cost \$\$

0.042
WATTS/SQ.FT.

2.8	4.6	2.9	2.1	3.7	4.2	2.3
5.8	16.5	6.0	3.0	10.9	13.8	3.7
3.9	7.9	4.0	2.5	5.7	7.0	2.8
2.2	3.0	2.3	1.9	2.7	2.9	2.0
3.8	7.8	3.9	2.4	5.7	7.0	2.8
5.6	16.4	5.8	2.9	10.1	13.6	3.5
2.4	4.1	2.4	1.7	3.2	3.7	1.9

BETTER

- 4.8 fc avg - 1.7 fc min - 9.5 max/min
- Equipment Cost \$\$
- Labor cost \$\$

0.054
WATTS/SQ.FT.

2.2	2.3	2.2	2.2	2.2	2.3	2.2
3.3	3.7	3.4	3.2	3.4	3.7	3.3
6.5	7.6	6.8	5.8	6.8	7.6	6.5
9.4	10.3	9.7	8.7	9.7	10.3	9.4
9.2	10.1	9.5	8.4	9.5	10.1	9.2
6.0	7.0	6.3	5.4	6.3	7.0	6.0
3.1	3.4	3.2	3.0	3.2	3.4	3.1

BEST

- 5.5 fc avg - 1.8 fc min - 5.7 max/min
- Equipment Cost \$\$
- Equipment Cost \$
- Labor Install cost \$

0.045
WATTS/SQ.FT.

Typical area of analysis - 32,500 square foot
60 FT standard parking bay with 30 FT driveway
9 FT ceiling

Emergency Lighting Is Not A Choice, **It Is The Law!**

But how do you comply NFPA 101 with T24 requirements that have fixture embedded sensors? **Look below.**

CODE NFPA 101: Emergency lighting must remain illuminated for at least 90 minutes. Illumination levels are allowed to decline to an average of 0.6 fc, with a 0.06-fc minimum, at the end of the 90-minute period. NFPA 101 7.9.

Performance Lighting Systems



VCPG Luminaire

huge \$\$ savings!

- 0-10VDC dimmable luminaire
- Integrated occupant/photo sensor
- CA T24 compliant & UL924 EM listed

- Fed with single EM hot!
- No EM Shunt Relay required!
- Power Interruption > 50 ms lights FULL ON 90mins

+



Inverter

- CA T24 Compliant UL924 Inverter
- Provides 50 ms minimum transfer time

OTHERS



- Luminaires by others**
- 0-10VDC Dimmable
 - Option to have integrated sensor device.

+



- EM Shunt**
- Required per fixture;
 - Externally mounted to avoid UL complications
 - \$\$\$ costly*

+



- Extra Hot**
- Required for sensing loss of power
 - Requires separate conduit
 - \$\$\$ costly*

+



Inverter